



FLANGETYTE GASKETS BY U.S. PIPE SHALL BE USED FOR ALL FLANGED FITTINGS. INSULATING GASKETS SHALL BE TYPE E 1/8" THICK FULL-FACED NEOPRENE PHENOLIC GASKETS INSTALLED WITH GRADE G-10 FIBERGLASS EPOXY INSULATING BOLT SLEEVES AND WASHERS.

SERVICE LINE INSTALLATION

ALTERNATE MATERIALS MUST BE APPROVED BY THE CITY OF NAPA WATER DIVISION PRIOR TO USE

APPROVED FITTINGS	
DESCRIPTION	MUELLER
INSULATED CORP. STOP (CC x COMP)	N-35008
COUPLING (COMP x FIP)	H-15451
90° BEND (COMP x COMP)	H-15526

** EXCEPT FOR INSULATED FITTINGS, FORD OR JONES EQUIVALENT ALSO APPROVED

NOTES

- CITY INSTALLATION ENDS AT INSULATING FITTING (AT BACK OF CURB). CONTRACTOR SHALL BE RESPONSIBLE FOR SERVICE INSTALLATION FROM INSULATING FITTING TO BACKFLOW DEVICE. ENCROACHMENT PERMIT REQUIRED.
- FIRE SERVICES SUPPLYING WATER TO PRIVATE FIRE HYDRANTS OR FIRE STORAGE TANKS SHALL BE INSTALLED WITH A DETECTION METER AT THE BACK OF CURB (SEE W-4E). METER BOX AND SERVICE LATERAL SHALL BE INSTALLED 3-FT (MIN) OUTSIDE OF DRIVEWAY, DRIVEWAY APPROACHES, AND OTHER VEHICULAR ACCESS WAYS.
- SERVICE LATERAL FROM MAIN TO METER SHALL BE 2-INCH COMPOSITE CPVC OR TYPE "K" SOFT COPPER PIPE.
- ALL BURIED SECTIONS OF METALLIC PIPE AND FITTINGS SHALL BE WRAPPED WITH AN 8-MIL PLASTIC SLEEVE. COPPER PIPE NOT WRAPPED IN A PLASTIC SLEEVE SHALL BE NSF 61 APPROVED PLASTIC COATED COPPER TUBING (TYPE "K" SOFT, BLUE IN COLOR). BURIED INSULATING GASKET AND COUPLING SHALL BE WRAPPED WITH 10-MIL HIGH TACK PIPE WRAP TAPE 3-FT (MIN) TO EACH SIDE OF THE INSULATION POINTS.
- EXISTING WATER MAINS SHALL BE HOT-TAPPED BY CITY FORCES AT DEVELOPER'S EXPENSE. HOT-TAP INCLUDES SADDLE VALVE, G5 BOX, PVC RISER, AND MISC. FITTINGS. SEE W-16 FOR HOT-TAP REQUIREMENTS. HOT-TAP SHALL BE INSTALLED 36-IN (MIN) FROM ANY TAP, BELL, FITTING, OR OTHER WATER SERVICE.
- APPROVED BACKFLOW PREVENTION DEVICES SHALL BE INSTALLED AND TESTED, AND WATER METERS (IF APPLICABLE) SHALL BE SET, PRIOR TO ANY USE OF WATER SERVICE. USE OF JUMPERS, HOSE BIBS, OR OTHER DEVICES SHALL NOT BE PERMITTED.
- METERS SHALL BE PLACED A MINIMUM OF 3-FT FROM ANY OBSTRUCTION (SIGN POST, MAIL BOX, FENCES, WALLS, ETC.). NO TREES SHALL BE PLANTED WITHIN 10-FT OR LARGE SHRUBS WITHIN 5-FT OF THE METER BOX. SEE W-18 FOR ADDITIONAL REQUIREMENTS.
- ONLY PRIVATE FIRE PROTECTION SYSTEMS (INCLUDING BUT NOT LIMITED TO FIRE SPRINKLERS AND FIRE HYDRANTS) SHALL BE CONNECTED TO FIRE SERVICES. OTHER USES MUST BE SERVED FROM STANDARD METERED WATER SERVICES. FIRE SERVICES WITH DETECTION METERS DO NOT QUALIFY AS STANDARD METERED WATER SERVICES.
- FIRE SERVICE LATERAL SIZE SHALL NOT EXCEED THE SIZE OF THE PUBLIC WATER MAIN THAT SERVES THE FIRE SERVICE. THE FIRE SERVICE SHALL BE SIZED SUCH THAT FIRE FLOW DEMANDS DO NOT EXCEED A 10-FT/SEC FLOW RATE THROUGH THE FIRE SERVICE LATERAL.

CITY OF NAPA

PUBLIC WORKS - WATER DIVISION

**2" FIRE SERVICE
(CI AND DIP WATER MAINS)**

DATE REVISED: DECEMBER 2015

CHECKED: *[Signature]*

APPROVED: *[Signature]*

SCALE: NONE

DWG NO.

W - 4A