

CITY OF NAPA

PUBLIC WORKS - WATER DIVISION

**INTERIOR DOUBLE CHECK VALVE  
BACKFLOW DEVICE INSTALLATION FOR  
2" FIRE WATER SERVICES**

DATE REVISED: DECEMBER 2015

CHECKED:

APPROVED:

SCALE:

*[Handwritten signatures and initials]*

NONE

DWG NO.

**W - 7B.1**

**NOTES**


1. DOUBLE CHECK VALVE MUST BE INSTALLED IN A TRUE HORIZONTAL POSITION.
2. BACKFLOW DEVICE MUST BE INSTALLED BEHIND THE BACK OF SIDEWALK OUTSIDE OF THE PUBLIC RIGHT-OF-WAY AND PROTECTED FROM TRAFFIC HAZARDS, EITHER BY LOCATION OR BARRIERS.
3. NO CONNECTIONS ARE ALLOWED BETWEEN THE WATER MAIN AND THE DOUBLE CHECK VALVE ASSEMBLY. A THERMAL EXPANSION RELIEF VALVE SHALL BE INSTALLED BETWEEN BACKFLOW DEVICE AND WATER HEATERS BEING SERVED.
4. ALL PARTS MUST BE EASILY ACCESSIBLE FOR INSPECTION BY THE WATER DIVISION CROSS CONNECTION SPECIALIST.
5. ANY OTHER LOCATION OR METHOD OF INSTALLATION MUST BE APPROVED IN ADVANCE BY THE WATER DIVISION CROSS CONNECTION SPECIALIST.
6. ALL BURIED SECTIONS OF METALLIC PIPE AND FITTINGS SHALL BE WRAPPED WITH AN 8-MIL PLASTIC SLEEVE BETWEEN THE WATER MAIN AND THE BACKFLOW DEVICE. COPPER PIPE NOT WRAPPED IN A PLASTIC SLEEVE SHALL BE NSF 61 APPROVED PLASTIC COATED COPPER TUBING (TYPE "K", BLUE IN COLOR). INSULATED FITTINGS SHALL BE WRAPPED WITH 10-MIL HIGH TACK PIPE WRAP TAPE 3-FT (MIN) TO EACH SIDE OF INSULATION POINT. WRAPPING METALLIC PIPE AND FITTINGS BEYOND THE BACKFLOW DEVICE IS RECOMMENDED, BUT NOT REQUIRED.
7. INSTALLATION MUST BE APPROVED BY THE WATER DIVISION CROSS CONNECTION SPECIALIST AND THE DEVICE TESTED BY A CITY APPROVED AWWA CERTIFIED BACKFLOW TESTER BEFORE WATER IS TURNED ON.
8. DOUBLE CHECK ASSEMBLY MUST BE APPROVED BY THE CALIFORNIA DEPARTMENT OF HEALTH SERVICES.
9. NO TREES SHALL BE PLANTED WITHIN 10-FT, OR LARGE SHRUBS WITHIN 5-FT, OF DOUBLE CHECK VALVE.
10. APPROVED BACKFLOW PREVENTION DEVICES SHALL BE INSTALLED AND TESTED PRIOR TO ACTIVATION OF SERVICE. USE OF JUMPERS, HOSE BIBS, OR OTHER DEVICES SHALL NOT BE PERMITTED.
11. THE FIRE DEPARTMENT CONNECTION AND RELATED APPURTENANCES SHALL MEET THE CITY OF NAPA FIRE DEPARTMENT SPECIFICATIONS AND REQUIREMENTS. LOCATION OF THE FIRE DEPARTMENT CONNECTION SHALL BE APPROVED BY THE NAPA FIRE DEPARTMENT.
12. BACKFLOW DEVICE CAN BE INSTALLED WITHIN A BUILDING IN A DEDICATED UTILITY CLOSET IF THE BUILDING IS LOCATED WITHIN 20-FT OF THE PUBLIC RIGHT-OF-WAY, THE BACKFLOW DEVICE IS PLACED AT THE CORNER OF THE BUILDING CLOSEST TO THE PUBLIC RIGHT-OF-WAY WHERE THE CONNECTION IS MADE, AND WITH THE APPROVAL FROM THE WATER DIVISION CROSS CONNECTION SPECIALIST. THE BACKFLOW DEVICE MUST BE APPROVED BY AWWA FOR VERTICAL INSTALLATION.
13. PIPE INSTALLATION TO THE BACKFLOW DEVICE SHALL MEET CITY STANDARD REQUIREMENTS FOR PUBLIC WATER MAINS (INCLUDING, BUT NOT LIMITED TO, CORROSION PROTECTION, SAND BEDDING, AND PRESSURE TESTING). CONTRACTOR IS RESPONSIBLE FOR CONTACTING WATER DIVISION INSPECTOR FOR INSPECTION OF PIPE INSTALLATION AND TESTING FROM THE CONNECTION AT THE WATER METER TO THE BACKFLOW DEVICE.
14. DRAINAGE SHALL BE PROVIDED IN THE UTILITY CLOSET (AS REQUIRED BY THE BUILDING DIVISION) TO DRAIN WATER THAT MAY BE RELEASED FROM THE TESTING OR DRAINAGE OF THE BACKFLOW DEVICE.
15. VERTICAL INSTALLATIONS SHALL HAVE A MINIMUM CLEARANCE OF 3-FT FROM THE FRONT OF THE DEVICE AND 18-IN TO EACH SIDE OF THE DEVICE FROM ANY STRUCTURE, UTILITY, OR OTHER FEATURE FOR ACCESSIBILITY.


CITY OF NAPA

PUBLIC WORKS - WATER DIVISION

**INTERIOR DOUBLE CHECK VALVE  
BACKFLOW DEVICE INSTALLATION FOR  
2" FIRE WATER SERVICES**

DATE REVISED: DECEMBER 2015

CHECKED: 

APPROVED: 

SCALE: NONE

**W - 7B.2**  
DWG NO.