



PLAN

PROFILE

NOTES

1. HOT-TAPS REQUIRED WHEN NEW MAINS OR SERVICE LATERALS ARE CONNECTED TO EXISTING WATER MAINS. ALL HOT TAPS SHALL BE BY CITY FORCES AT THE CONTRACTOR'S EXPENSE.
2. CONTRACTOR SHALL PROVIDE SAWCUTTING, EXCAVATION, BACKFILL, COMPACTION, PLATING, PAVING, TRAFFIC CONTROL, AND ENCROACHMENT PERMIT.
3. CONTRACTOR SHALL PROVIDE AND INSTALL SHORING PER OSHA STANDARDS.
4. THE CONTRACTOR SHALL MODIFY SITE CONDITIONS TO THE SATISFACTION OF THE CITY REPRESENTATIVE.
5. HOT TAPS FOR 1.5" AND 2" WATER SERVICES WILL BE MADE WITH A 4" TAPPING SADDLE AND GATE VALVE. THE CITY WILL INSTALL FITTINGS SO THAT CONTRACTOR CAN CONNECT TO A 2" COMPRESSION FITTING.
6. FOR 1" HOT-TAPS, 7' DIMENSION CAN BE REDUCED TO 5'.
7. FEES SHALL BE PAID AT THE WATER DIVISION OFFICE LOCATED AT 1340 CLAY ST. FOR QUESTIONS REGARDING FEES, CALL (707) 257-9521.
8. AFTER FEES HAVE BEEN PAID, ALLOW 7 TO 10 WORKING DAYS FOR SCHEDULING HOT-TAP INSTALLATION.
9. TO SCHEDULE A HOT-TAP AFTER FEES HAVE BEEN PAID, CALL (707) 257-9544.
10. IF EXISTING UTILITIES EXIST WITHIN THE HOT TAP EXCAVATION PIT AND INHIBIT CITY CREWS FROM COMPLETING HOT TAP, CONTRACTOR MAY BE REQUIRED TO MODIFY EXISTING WATER MAIN, TO CUT IN NEW TEE FOR WATER SERVICE, OR RELOCATE EXISTING UTILITIES. MODIFICATIONS TO WATER FACILITIES SHALL BE DETERMINED BY WATER DIVISION STAFF.

CITY OF NAPA

PUBLIC WORKS - WATER DIVISION

HOT-TAP DETAIL

DATE REVISED	DECEMBER 2015
CHECKED	<i>[Signature]</i>
APPROVED	<i>[Signature]</i>
SCALE	NONE

DWG NO. **W - 16**