



NOTES:

1. THE USE OF NON-METALLIC PIPE AS AN ALTERNATE MATERIAL TO DUCTILE IRON MUST BE APPROVED BY THE CITY OF NAPA WATER DIVISION PRIOR TO USE.
2. THIS DETAIL IS TYPICAL OF ELBOWS, REDUCERS & OTHER FITTINGS.
3. MULTIPLE FITTINGS MAY BE BONDED TOGETHER AND PROTECTED WITH ONE ANODE PER DRAWING W-25C.
4. NO TEST STATION IS REQUIRED FOR THESE FITTINGS, HOWEVER A RECORD OF ALL INSTALLATIONS SHALL BE PROVIDED TO THE PROJECT ENGINEER.

CITY OF NAPA

PUBLIC WORKS - WATER DIVISION

FITTING - ANODE INSTALLATION

DATE REVISED DECEMBER 2015

CHECKED *[Signature]*

APPROVED *[Signature]*

SCALE NONE

DWG NO.

W - 24B