



NOTES:

1. THE USE OF NON-METALLIC PIPE AS AN ALTERNATE MATERIAL TO DUCTILE IRON MUST BE APPROVED BY THE CITY OF NAPA WATER DIVISION PRIOR TO USE.
2. THE ANODE SHALL BE INSTALLED VERTICALLY OR HORIZONTALLY WITH THE TOP OF THE ANODE 5 FT. BELOW GRADE AND 3 FEET BELOW PIPE.

CITY OF NAPA

PUBLIC WORKS - WATER DIVISION

VERTICAL OFFSETS - ANODE INSTALLATION

DATE REVISED DECEMBER 2015

CHECKED *[Signature]*

APPROVED *[Signature]*

SCALE

NONE

DWG NO.

W - 24C