



NOTES:

1. NUMBER AND SIZE OF ANODES SHALL BE DETERMINED BY THE PROJECT CORROSION ENGINEER.
2. IDENTIFY CABLES PER DRAWING W-26C.
3. INSTALL THE REFERENCE CELL BETWEEN THE TWO PIPELINES.
4. PERMISSION MUST BE OBTAINED FROM THE FOREIGN PIPELINE OWNER PRIOR TO ATTACHMENT OF TEST WIRES.

CITY OF NAPA

PUBLIC WORKS - WATER DIVISION

FPTS - FOREIGN PIPELINE TEST STATION

DATE REVISED DECEMBER 2015

CHECKED

APPROVED

SCALE

NONE

DWG NO.

W - 27B