



**NOTES:**

1. THE USE OF NON-METALLIC PIPE AS AN ALTERNATE MATERIAL TO DUCTILE IRON MUST BE APPROVED BY THE CITY OF NAPA WATER DIVISION PRIOR TO USE.
2. INSTALL ANODE A MINIMUM OF 3-FEET FROM VALVE.
3. IDENTIFY CABLES PER DRAWING W-26C.

CITY OF NAPA

PUBLIC WORKS - WATER DIVISION

**VALVE - ANODE TEST STATION**

DATE REVISED DECEMBER 2015

CHECKED *[Signature]*

APPROVED *[Signature]*

SCALE NONE

**W - 28C**

DWG NO.