



NOTES:

1. THE USE OF NON-METALLIC PIPE AS AN ALTERNATE MATERIAL TO DUCTILE IRON MUST BE APPROVED BY THE CITY OF NAPA WATER DIVISION PRIOR TO USE.
2. INSTALL ANODE A MINIMUM OF 3 FEET FROM VALVE.
3. IDENTIFY CABLES PER DRAWING W-26C.

CITY OF NAPA

PUBLIC WORKS - WATER DIVISION

CROSS - ANODE TEST STATION

DATE REVISED DECEMBER 2015

CHECKED

APPROVED

SCALE

NONE

DWG NO.

W - 28D